

Calculation of requirements for Air Conditioning Systems on a typical floor of Menara Suara Merdeka

by Previari Pramesti

Submission date: 25-Feb-2023 03:45PM (UTC+0700)

Submission ID: 2022686409

File name: itioning_Systems_on_a_typical_floor_of_Menara_Suara_Merdeka.docx (67.69K)

Word count: 1668

Character count: 8134

Calculation of requirements for Air Conditioning Systems on a typical floor of Menara Suara Merdeka

Previari Umi Pramesti^{1*}, Muhammad Ismail Hasan², Bintang Noor Prabowo³ and Hermin Werdiningsih⁴

¹ Vocational School, Universitas Diponegoro, Indonesia

² Faculty of Built Environment, University of Malaya, Malaysia

³ Department of Civil and Environment Engineering, Norwegian University of Science and Technology, Norway

⁴ Faculty of Engineering, Universitas Diponegoro, Indonesia

*previariumpramesti@lecturer.undip.ac.id

Received: 1st May 2021

Final version received: 3rd Jun 2021

Abstract: This research discusses the calculation of the heat load on the air conditioning system in buildings, which can determine the value of the energy consumption. Air conditioning is the treatment of air to regulate temperature, humidity, cleanliness and distribution simultaneously to achieve the comfortable conditions required by people in a room. This research aims to design air conditioning at Menara Suara Merdeka Semarang, which has a typical floor so that it creates comfortable conditions in the entire room. The cooling load calculated from a simulation from different factors between the highest and lowest TE ° on the 9th and 10th floors of the Menara Suara Merdeka Semarang building as a floor represents the overall condition of this building. Based on the calculations that have been done, it is found that the energy load is $7.35605 \text{ K cal} \times 1.163 = 8.5550 \text{ Watt (per m}^3\text{)}$. The next calculation results show that the air conditioning application for this type of room is to install 8 Fan Coil Units (FCUs), each with a capacity of 8 Pk.

Keywords: Air Conditioning, Cooling Load

1. INTRODUCTION

To create comfortable conditions for the body, humans try to make a building that can protect against extreme climates, for example, hot air and sunburn, or freezing air. The air conditioning that we know today in every room in the building is Air Conditioning (AC). AC is a tool that functions to condition the air. It can be said that AC is a device that functions as an air conditioner and air regulator. Air conditioning in the room is intended to obtain the desired air temperature (cool or cold) and comfortable for the

body (Abdurachman, 2018). Air conditioning usage also affects how green the building is (Almeida et al., 2020) (Lee et al., 2019).

This study examines and analyzes the calculation steps for an air conditioning system following the building's situation and condition with a typical floor, precisely at the Menara Suara Merdeka Semarang building. One of the high-rise buildings in the city of Semarang is the Menara Suara Merdeka Building, this building is located on Jalan Pandanaran Semarang, which is a building belonging to the Suara Merdeka Group which functions as an office rent building. The 15-

storey building with 2 basements consists of an entrance area, an office area, a parking area and a management office area. One of the skyscrapers in Semarang has a modern style, which is visible with a facade that is minimal in ornamentation and the use of fabricated materials which is dominated by glass. Stop-sol glass and reflective glass reduce the sun's heat transfer entering the room in modern buildings in the tropics. The building, which has a south-oriented façade, is dominated by the use of Stopsol glass in the east and reflective glass on the south, west and north sides. The majority of the rooms in this building function as rental offices that ensure that its users' comfort is the main requirement. Thus, the room needs a proper air conditioning calculation to provide comfort (O'Brien et al., 2011) (Wesołowska & Laska, 2018).

In this connection, several things must be known, such as when and where the peak load occurs in the air conditioning system itself. To obtain an efficient operation of the air conditioning system without sacrificing the room's comfort and environment, a detailed calculation analysis is needed to obtain energy and economic efficiency by optimizing the air conditioning system's capacity as needed (Rock, 2018). Air conditioning is the regulation of air conditions that include temperature, humidity, air quality, and circulation simultaneously to achieve the occupants' comfortable conditions (McQuiston et al., 2005). Air conditioning must control the desired air temperature for each time, and in principle, this conditioning system's working process is about heat, namely adding or removing a certain amount of heat from the conditioned place. The air conditioning of a room is usually determined by (1) the amount of humidair to be supplied, and (2) the condition of the supply air required to remove a certain amount of energy and water from the room (ASHRAE Standard 2001).

An air conditioning system is composed of components and equipment arranged in sequence to condition the air, transport it to the conditioned space, and control the indoor environmental parameters of a specific space within required limits (Wang, 2001). Most air conditioning systems perform the following functions: 1. Provide the cooling and heating energy required 2. Condition the supply air, that is, heat or cold, humidify or dehumidify, clean

and purify, and attenuate any objectionable noise produced by the HVAC & R equipment 3. Distribute the conditioned air, containing sufficient outdoor air, to the conditioned space 4. Control and maintain the indoor environmental parameters – such as temperature, humidity, cleanliness, air movement, sound level, and the pressure differential between the conditioned space and surroundings — within predetermined limits

2. METHODOLOGY

The first stage is to search for literature related to AC design. Research remained data collection such as the condition of the 10th floor as an empty floor, and the condition of the 9th floor as occupied floor. The last stage is processing the data that has been made where the data can be determined the cooling load per room which is then totalled to determine the right cooling machine.

3. FINDING AND DISCUSSION

Calculation of Heat Load in Building Conditioning Systems

This calculation is done to determine the energy consumption required to condition the room air with the ratio of the room on the 10th floor that has not been used and the room on the 9th floor that has been fully used. On the 10th floor, the adequate temperature conditions and relative humidity in the field are obtained as follows:

Table 1. Room Temperature and Humidity at 10th floor

Time	08.00	09.00	10.00	11.00	12.00	13.00	14.00	15.00	16.00
ET°C	29.6	30.9	31.5	31.2	31.3	31.3	30.6	30.6	30.4
Hum	63	61.2	59.3	61.7	61.7	66.9	61.7	62.7	63.5

If the highest TE° taken is at 13.00, namely 31.3°C with RH 66.9%. TE° 31.3°C in a saturated state contains 32.080 grams of water, so:

RH 66.9% = 66.9% x 32.080 = 21.462 grams of water.

On the 9th floor, the following field conditions are obtained:

Table 2. Room Temperature and Humidity at 9th floor

Time	08.00	09.00	10.00	11.00	12.00	13.00	14.00	15.00	16.00
ET°C	28.56	29.16	27.61	25.37	23.71	25.32	26.2	27.58	23.52
Hum	58.62	49.5	51.25	53.75	55.5	53.5	53.37	51.42	57

To take the lowest TE° is at 16.00 which is 23.52°C with RH 57%. TE° 23.52°C in a saturated state contains 21.810 grams of water, so:

$$RH\ 57\% = 57\% \times 21,810 = 12,432\ \text{grams of water.}$$

Thus, the water to be evaporated = 21.462 - 12.432 = 9.03 grams of water.

Provided that the heat needed to evaporate 1 gram of water is 0.61 K cal, then:

To evaporate 9.03 grams of water, you need calories/energy of: 0.61 K cal x 9.03 = 5.5083 K cal(a)

1 m³ of dry air 31.3 °C to 23.52 °C there is a difference of 7.78 °C.

The specific heat of dry air = 0.2375 K cal, so to dry the air with a temperature difference of 7.78 °C it takes calories/energy of:

$$7.78 \times 0.2375 = 1.84775\ \text{K cal(b)}$$

So that to cool 1 m³ of air from 31.3°C with RH 66.9% to 23.52°C with RH 57%, it takes heat of:

$$+ (b) = 5.5083 + 1.84775 = 7.35605\ \text{K cal(equation 1)}$$

To convert the energy / calorie value needed into Watts, then: Convert 1 K cal = 1.163 Watt, so that 7.35605 K cal when converted into Watt will be worth: 7.35605 K cal x 1.163 = 8.5550 Watt (per m³).

Calculation of Room Cooling Energy Needs

Based on Lippsmeier's research and the research of the LPMB PU Foundation regarding the distribution of comfortable temperatures for

Indonesians, the temperature needed to be able to activities properly is at the optimal comfortable temperature (22.8 ° C - 25.8 ° C with 70% humidity). It indicates that the condition of the 10th floor of Menara Suara Merdeka is not involved in the optimal comfort criteria (Lippsmeier, 1997). Hence, the room requires artificial air conditioning such as AC with proper calculation as follow:

$$\text{Needs of BTU} = (W \times H \times I \times L \times E) / 60 \dots\dots\dots(\text{equation 2})$$

BTU : British Thermal unit (unit of AC requirement) W: Length of room (in feet)

H : Height (in feet)

I : Value 10 if the room is insulated (on the lower floor, or coincide with another room). Score 18 if the room is uninsulated (upstairs).

L : Width (in feet)

E : Value 16 if the longest wall faces north; score 17 if facing east; Score 18 if facing south; and a value of 20 if facing west.

$$\text{Needs of BTU} = 541.399,27\ \text{BTU}$$

Known,

$$AC\ \frac{1}{2}\ \text{PK} = \pm 5,000\ \text{BTU} / \text{h}$$

$$AC\ \frac{3}{4}\ \text{PK} = \pm 7,000\ \text{BTU} / \text{h}$$

$$AC\ 1\ \text{PK} = \pm 9,000\ \text{BTU} / \text{h}$$

$$AC\ 1\frac{1}{2}\ \text{PK} = \pm 12,000\ \text{BTU} / \text{h}$$

$$AC\ 2\ \text{PK} = \pm 18,000\ \text{BTU} / \text{h}$$

$$1\ \text{Pk} = 735.5\ \text{watts} / \text{hour}$$

So it can be assumed that the special energy requirements for cooling the room are,

$$\text{Energy} = \text{BTU} / 9,000 \times \text{energy 1Pk} \dots\dots\dots(\text{equation 3})$$

$$= 541,399.27 / 9,000 \times 735.5$$

$$= 44,244.35\ \text{Watt} / \text{hour}$$

With an energy requirement of 44,244.35 Watt / hour, the air conditioning application for this type of room is to install 8 Fan Coil Units (FCUs), each with a capacity of 8 Pk.

8 FCU @ 8 Pk @ 735,5 Watt/jam 47.072 Watt Jam

4. CONCLUSION

In the conditions above, an attempt to cool 1 m³ of air from 31.3 ° C with RH 66.9% to 23.52 ° C with RH 57% requires a heat of 7.35605 K cal. If the energy/calorie value needed is converted into Watts, the value is 8.5550 Watt (per m³). The special energy requirement for cooling the room is 44,244.35 Watt/hour. With an energy requirement of 44,244.35 Watt/hour, the air conditioning application for this type of room is to install 8 Fan Coil Units (FCUs), each with a capacity of 8 Pk.

5. REFERENCES

- Abdurrachman, H. (2018). Perancangan AC Sentral pada Gedung G Institut Teknologi Indonesia. *Jurnal Teknik Mesin ITI*, 2(2), 35–41.
<https://doi.org/10.31543/jtm.v2i2.156>
- Almeida, L., Tam, V. W. Y., Le, K. N., & She, Y. (2020). Effects of occupant behaviour on energy performance in buildings: a green and non-green building comparison. *Engineering, Construction and Architectural Management*, 27(8), 1939–1962. <https://doi.org/10.1108/ECAM-11-2019-0653>
- Ashrae Standard. (2001). ASHRAE Handbook 2001 Fundamentals. *Ashrae Standard*, 53(9), 1689–1699.
- Lee, K. Y., Chu, Y. M., Chen, C. C., Tsai, C. L., & Lou, S. J. (2019). Case Analysis on Energy Saving Improvement of Commercial Air Conditioning Systems. *2019 IEEE Eurasia Conference on IOT, Communication and Engineering, ECICE 2019*, 306–309.
<https://doi.org/10.1109/ECICE47484.2019.8942775>
- Lipsmeier, G. (1997). *Bangunan Tropis*. Erlangga.
- McQuiston, F. C., Jerald D. Parker, & Jeffrey D. Spitler. (2005). Heating, Ventilating, and

Air Conditioning Analysis and Design. In *John Wiley & Sons, Inc.* (Vol. 6).

- O'Brien, W., Athienitis, A., & Kesik, T. (2011). Thermal zoning and interzonal airflow in the design and simulation of solar houses: A sensitivity analysis. *Journal of Building Performance Simulation*, 4(3), 239–256.
<https://doi.org/10.1080/19401493.2010.528031>
- Rock, B. A. (2018). Thermal zoning for HVAC design. *ASHRAE Journal*, 60(12), 20–30.
- Wang, S. K. (2001). Air Conditioning Systems: System Classification, Selection, and Individual Systems. In *Handbook of Air Conditioning and Refrigeration*.
- Wesołowska, M., & Laska, M. (2018). Assessment of thermal comfort in lecture room by chosen calculation methods. *E3S Web of Conferences*, 44.
<https://doi.org/10.1051/e3sconf/20184400186>

Calculation of requirements for Air Conditioning Systems on a typical floor of Menara Suara Merdeka

ORIGINALITY REPORT

18%

SIMILARITY INDEX

15%

INTERNET SOURCES

10%

PUBLICATIONS

12%

STUDENT PAPERS

PRIMARY SOURCES

1	de.scribd.com Internet Source	6%
2	www.coursehero.com Internet Source	2%
3	edoc.site Internet Source	2%
4	www.ibpsa.org Internet Source	2%
5	strathprints.strath.ac.uk Internet Source	1%
6	Submitted to Universitas Muhammadiyah Surakarta Student Paper	1%
7	Submitted to Oregon State University Student Paper	1%
8	online.etems.digital Internet Source	1%

9 Magdalena Baborska-Narożny, Marta Laska, Natalia Fidorów-Kaprawy, Martyna Mokrzecka et al. "Thermal comfort and transition from solid fuel heating in historical multifamily buildings — Real-world study in Poland", Energy and Buildings, 2021
Publication 1 %

10 rahadi-teknik.blogspot.com
Internet Source 1 %

11 talenta.usu.ac.id
Internet Source 1 %

12 Submitted to Universiti Teknologi Malaysia
Student Paper <1 %

13 link.springer.com
Internet Source <1 %

Exclude quotes On

Exclude matches Off

Exclude bibliography On

Calculation of requirements for Air Conditioning Systems on a typical floor of Menara Suara Merdeka

GRADEMARK REPORT

FINAL GRADE

/0

GENERAL COMMENTS

Instructor

PAGE 1

PAGE 2

PAGE 3

PAGE 4
